



Monitor

Configuration

Graph

E10017210353

ABH1002_Y



IS Storage 1Play
RS485 1

Register on
INGECON
SUN Monitor

Categories

search for...

search

1- DC BATTERY TYPE

1.1- Lead-Acid Battery Settings

2- AC INSTALLATION TYPE

3- GENERATOR SETTINGS

4- GRID SETTINGS

4.1- Connection and Reconnection

5- NETWORK QUALITY SERVICES

5.1- Pac vs OverFac Algorithm

5.2- Pac vs UnderFac Algorithm

5.3- Pac vs OverVac Algorithm

5.5- Qac vs Vac Algorithm

5.6- CosPhi vs Pac Algorithm

5.7- LVRT and HVRT

6- OPERATION MODE

7- DIGITAL OUTPUT / INPUT

8- OTHER SETTINGS

8.1- Communication Settings

Inverter configuration check list

Please check marked setting



Off grid

Check next page

Off grid

Name	Value	
Type of Operation Mode	Self-Consumption managed by ISS1Play ▾	★
Battery-Backup Function : Mode	Enabled ▾	★
Low PV Power Stop : Mode	Disabled ▾	
SOCmax : Maximum charge limit of renewable source (%)	100	★
SOCgrid : Maximum charge limit from the grid/genset (%)	40	★
SOCmin : Minimum limit for switching to standby (%)	20	
SOCrecx : Value to generate voltage in the loads (%)	20	
SOCdescx : Minimum limit for switching to shutdown (%)	5	
Time for SOCdescx : Time for switching to shutdown (seconds)	80	
Maximum battery charging power from the grid (W)	500	★
Maximum power injected to the grid (W)	5000	★ Export limit

Reserve energy used only if generator or grid not available ★

